

DGT-Daff/11/2022-O/o DIR (TC)
Government of India
Ministry of Skill Development and Entrepreneurship
Directorate General of Training

Employment Exchange Building,
1st floor, Pusa, New Delhi,
Dated: -01.07.2022

To,

The Principal,
Sunrise Private ITI,
Purani Chungi, Agra Road,
Dist. - Jaipur, Rajasthan.
(MIS Code-PU08001497)

To,

The Principal,
Sunrise Private ITI, Dev Vihar, Gujaro Ka
Bass, Goner Road, Tehsil Sanganer, Dist. -
Jaipur, Rajasthan

SHOW CAUSE NOTICE FOR DE-AFFILIATION OF TRADES/UNITS/ITI

Sir/Madam,

Your ITI was affiliated since 2014 by DGT at Sunrise Private ITI, Purani Chungi, Agra Road, Dist.- Jaipur, Rajasthan. whereas your ITI was shifted to new location Sunrise Private ITI, Dev Vihar, Gujaro Ka Bass, Goner Road, Tehsil Sanganer, Dist. - Jaipur, Rajasthan without prior permission of the competent authority, it self-deemed to be violation of affiliation norms.

It is admitted position by you in WP - 1140/2020 that you have shifted to your ITI to new location i.e. Sunrise Private ITI, Dev Vihar, Gujaro Ka Bass, Goner Road, Tehsil Sanganer, Dist. - Jaipur, Rajasthan since dt. 05.08.2018 which attracts the de-affiliation of the Institute as per the affiliation norms, clause 3.5.1.

As per Court direction your WP - 1140/2020 for shifting of the ITI old location to new location considered by DGT and carried out inspection of your ITI. As per inspection team report *your ITI has not recommended for shifting and also found major deficiencies at new address*. The shortcomings are as follows: -

1. The Classrooms, workshops, IT Labs, administrative area, amenities areas are built in basement which is not allowed as per affiliation norms (8.0 General guidelines).
2. Electrician trade workshop shed is constructed with tin sheets which are not allowed as per affiliation norms.
3. Insulation mats were not available in the workshop.
4. Exhaust fans were not fitted in workshop.
5. Electricity bill is not in the name of ITI.
6. Group instructor recruited is one instead of two group instructors.
7. Rescue van was not fitted with lifesaving equipment's.
8. Only three instructors recruited instead of six instructors in the trade of Fire Technology and Industrial Safety Management.

You are therefore, requested to clarify why action should not be initiated to *de-affiliate your institute from old address which is shifting by you without any prior approval from DGT & State Directorate*.

➤ Your reply must reach this office within 15 days i.e. by 15.07.2022 positively.

Reply of Show Cause Notice to be sent on tc-deaffiliation@dgt.gov.in.



Your's faithfully


(Ujjwal Biswas)
Director of Training

- Note - This notice does not invalidate any other previous notice(s) served upon you.

Copy To: -

1. The Director, Directorate of Technical Education, W-6, Residency Road, Jodhpur-342001, Rajasthan.
2. TC Section, DGT Hqr. New Delhi, with requested to uploaded this order on NCVT MIS Portal respectively.

O/C
CR please issue
D-4-1-22
12/


01/7/22

(PM. Damodharam)
Assistant Director